

DECLARATION OF CONFORMITY

Manufacturer: SATEL Sp. z o.o.
ul. Budowlanych 66
80-298 Gdańsk
tel. (+48 58) 320-94-00
fax. (+48 58) 320-94-01

declare under sole responsibility that

product: MIO-400 - conventional input/output module

Product description: The MIO-400 module is used for supervision of fire protection equipment or fire protection systems and other devices, control of fire protection equipment or fire protection systems and other devices. It is designed to operate in the detection line of the ACSP-402 addressable fire alarm control panel.

meet the essential requirements of the following EU Directives:

EMC: 2014/30/EU



Following harmonized standards have been applied for conformity assessment

EMC/Immunity EN 50130-4:2011, EN IEC 61000-6-1:2019

EMC/Emissions EN 55032:2015, EN IEC 61000-6-3:2021, EN IEC 61000-3-2:2019

Gdańsk, Poland, 07.05.2024

A handwritten signature in blue ink, appearing to read 'Mikołaj LisKin'.

Mikołaj LISKIN
Head of Research Department