

DECLARATION OF CONFORMITY

Manufacturer: SATEL Sp. z o.o.
ul. Budowlanych 66
80-298 Gdańsk
tel. (+48 58) 320-94-00
fax. (+48 58) 320-94-01

declare under sole responsibility that

product: CSP-104 Fire alarm control panel

Product description: Conventional fire alarm control panel, 4 supervision lines

meet the essential requirements of the following EU Directives:

EMC: 2014/30/EU

LVD: 2014/35/EU



Following harmonized standards have been applied for conformity assessment

EMC/Immunity	EN 50130-4:2011, EN IEC 61000-6-1:2019
EMC/Emissions	EN 55032:2015, EN IEC 61000-6-3:2021, EN IEC 61000-3-2:2019
Electrical safety	EN IEC 62368-1:2020

Gdańsk, Poland, 30.12.2022

A handwritten signature in blue ink, appearing to read 'Mikołaj Liskin'. The signature is written in a cursive, slightly slanted style.

Mikołaj LISKIN
Head of Research Department